

	CODE SECTION	CODE CHANGE YEAR	MODIFICATION TO ADOPTION	NOTES REQUIRED ON PLANS	DETAILS REQUIRED ON PLANS	MISC. NOTES.
R101.2	'GRADE PLANE' DEFINITION	2009				
R101.2	NEW EXCEPTION FOR LIVE /WORK UNITS FROM IBC	2009				
R101.2	NEW EXCEPTION FOR OWNER OCCUPIED LODGING	2012				
R102.4	CLARIFIED REFERENCE STANDARS	2012				
R105.2	CLARIFIES ELECTRICAL REPAIRS WITH NO PERMIT REQUIRED	2009				
R105.2	FLOOR AREA FOR ACCESSORY STRUCTURES INCREASED TO 200 SQ FT. INCLUDES DECKS LESS THAN 30"	2009				
R105.2	FENCES EXEMPT FROM PERMIT RAISED TO 7'	2012				
R106.1.1	BRACED WALL LINES TO BE SHOWN ON PLANS.	2009		YES	YES	WILL BE REQUIRED TO SHOW AMOUNTS, METHODS, LOCATIONS, AND ATTACHMENT DETAILS PER BRACED WALL LINE.
R106.3.1	APPROVAL OF CONSTRUCTION DOCUMENTS	2009				NEW STAMPS FOR BUILDING DEPARTMENT 'REVIEWED FOR CODE COMPLIANCE'
R201.4	TERMS NOT DEFINED	2012	ADDED DEFINITION			
R202	DEFINITIONS ADDED, ATTIC AND HABITABLE ATTIC, REVISED LABELED AND LISTED	2009				
R202	DEFINITION ADDED STRUCTURAL INSULATED PANEL	2009				
R202	DEFINITION ADDED STRUCTURAL COMPOSITE LUMBER, MECHANICAL VENTILATION AND LOCAL EXHAUST	2009				
R301.1.1	ALTERNATE PROVISIONS MODIFICATION- LOG AND COLD FORMED STEEL	2009				
R301.2.1	WIND DESIGN CRITERIA	2012				
R301.2.1.1	DESIGN CRITERIA	2009				

R301.2.1.2	PROTECTION OF OPENINGS. GARAGE DOOR OPENINGS	2009				
R301.2.1.2	PROTECTION OF OPENINGS REVISION.	2012				
R301.2.1.5	TOPOGRAPHIC WIND EFFECTS	2009		YES	YES	
R301.2.2	SEISMIC PROVISION DROPPED TO A B CATEGORY	2012		YES		
R301.2.2	SESMIC PROVISION REORDERED	2009				
R301.2.3	SNOW LOADS- SIPS ADDED TO TABLES	2009				
R301.3	STORY HEIGHT. MAX STORY HEIGHT 11'7" FLOOR DEPTH MAY VARY	2009		YES	YES	
R301.5	MINIMUM UNIFORMLY DISTRIBUTED LIVE LOADS. ATTIC WITH STORAGE BOTTOM CORD HEIGHTS AND LIVE LOADS	2009 /2012		YES	YES	TRUSS CALCS WILL HAVE TO REFLECT THESES CHANGES.
R302.1	FIRE RESISTANT CONSTRUCTION TO LOT LINES	2009			YES	DISTANCES AND CONSTRUCTION TYPE WILL BE REQUIRED ON PLANS.
R302.1	FIRE RESISTANT CONSTRUCTION TO LOT LINES W/ SPRINKLERS	2012	SPRINKLER ADJUSTMENT TO VALUES		YES	DISTANCES AND CONSTRUCTION TYPE WILL BE REQUIRED ON PLANS.
R302.2	DWELLING UNIT SEPERATION MOVED FROM 317.2	2009			YES	DETAILS ARE REQUIRED
R302.2.2	PARAPETS IN DWELLING UNIT SEPERATION EXCEPTION	2012		YES	YES	NOTES AND DETAILS REQUIRED
R302.4	RATED PENETRATIONS FOR DWELLING UNIT SEPERATIONS LOCATION CHANGED.	2009		YES	YES	NOTES AND DETAILS REQUIRED.
R302.5	GARAGE OPENINGS AND SEPERATIONS MOVED	2009		YES		NOTES ONLY
R302.5.1	ADDED SELF-CLOSING DEVICE BACK IN	2012	HAD IN 2006 AS AN ADMENMENT	YES		NOTES ONLY
R302.6	GARAGE SEPERATION SECTION MOVED	2009		YES	YES	NOTES OR DETAILS SHOWN ON PLANS
R303	MECHANICAL VENTILATION, ADDED WHOLE HOUSE VENTILATION, CHANGED TO LOCAL EXAUST ON BATHS	2012		YES		CALCULATION AS REQUIRED BY M1507, SHOW ON PLANS
R303.5	VENTILATION INTAKE OPENINGS CLEARANCES TO EXHAUST LOCATIONS	2012		YES		NOTES ON PLANS
R305.1	MINIMUM CEILING HEIGHTS. CLARIFIED	2009		YES		
R308.1.1	INDETIFICATION OF MULTIPLE ASSEMBLIES IN GLAZING	2009		YES		
R308.3	HUMAN IMPACT LOADS AT GLAZING	2009		YES		
R308.4	HAZARDOUS LOCATIONS. FOR GLAZING CLARIFICATION OF SECTIONS	2009		YES		
R308.4	HAZARDOUS LOCATIONS RE GROUPING AND NUMBERING	2012		YES		

R308.4.5	ADDED GLAZING AND WET SURFACES.	2012		YES		VERIFY HOW IT MATCHES TO STATE STATUTES
R308.4.6	GLAZING ADJACENT TO STAIRS AND RAMPS.	2012		YES	YES	SHOW LOCATION LINES AS NEED WITH NOTES
R308.4.7	GLAZING NEXT TO BOTTOM OF STAIR LANDINGS	2012		YES	YES	SHOW LOCATION LINES AS NEED WITH NOTES
R309.5	GARAGE FIRE SPRINKLERS	2012		YES	Yes	FIRE SPRNKLERS REQUIRE SEPARATE FIRE SPRINKLER PLANS TO BE SUBMITTED TO THE FIRE DEPARTMENT.
R310.1	EMERGANCY ESCAPE AND RESCUE WINDOWS- ADDED FOR HABITABLE ATTICS.	2009		YES		NOTES ONLY
R310.1	EMERGANCY ESCAPE AND RESCUE WINDOWS- CLARIFIED 44" RULE TO SILL	2012		YES		NOTES ONLY
R310.2.2	WINDOW WELL DRAINAGE	2012			YES	
R311	MEANS OF EGRESS- REVISED SIZING LANDINGS AND LOCATIONS.	2009		YES	YES	DETAILS AND NOTES ON PLANS
R311.3.1	FLOOR ELEVATION AT EGRESS DOOR	2012		YES	YES	DETAILS AND NOTES ON PLANS
R311.7.2	STAIRWAY HEADROOM, HEAD ROOM LINE AND PROJECTIONS	2009		YES	YES	DETAILS AND NOTES
R311.7.3 & 7.4	ADDED WALK LINES , DEFINISONS OF WHEN RISE AND RUN ARE MEASURED.	2009		YES	YES	CHANGE TO ROUGH FOR MEASUREMENT
R311.7.5	STAIR TREAD AND RISER, RISER OPENINGS, WALK LINES, WINDER AND NOSINGS	2012		YES	YES	
R311.7.6	LANDINGS FOR STAIRWAYS.	2012		YES	YES	
R 311.7.7	HANDRAILS, TURNOUT HEIGHTS GREATER THAN 36"	2009		YES	YES	
R312	GUARD LOCATIONS AND HEIGHTS,	2009	ADD CABLE RAILS HERE		YES	
R312	GUARD AND WINDOW FALL PROTECTIONS, MOVED INTO GALZING SECTION	2012		YES	YES	
R313	FIRE SPRINKLERS	2009	HAD AS AN AMENDMENT IN 2006,			PLANS SUBMITTED TO FIRE IF REQUIRED. AMMENDED IN 2006 CODE.
R314	SMOKE ALARMS, ADDED FIRE WARNING/ALARM SYSTEMS	2009		YES	YES	

R314	SMOKE ALARMS WIRELESS	2012		YES	YES	
R315	ADDED CARBON MONOXIDE ALARMS	2009		YES	YES	DETAILS AND NOTES ON PLANS
R315.2	ADDED CARBON MONOXIDE DETECTION SYSTEMS.	2012		YES	YES	DETAILS AND NOTES ON PLANS
R316.4	THERMAL BARRIER REQUIREMENTS WITH NEW TESTING.	2012		YES	YES	DETAILS AND NOTES ON PLANS
R316.5.13	THERMAL BARRIER FOR FLOORS, SIPS REQUIREMENTS	2012		YES	YES	DETAILS AND NOTES ON PLANS
R317.1	LOCATIONS FOR PROTECTION AGAINST DECAY, LESS THAN 2 IN ABOVE SLAB	2009		YES	YES	DETAILS AND NOTES ON PLANS
R317.3	ADDED, FASTNERS AND CONNECTOR FOR TREATED WOODS.	2009		YES	YES	
R317.4	ADDED, WOOD PLASTIC COMPOSITES	2009		YES	YES	PROVIDE CUT SHEET OF PRODUCT USED. AND SPAN TABLE IF USING AS STAIR TREADS.
R 318.1	SUBTERRANEAN TERMITE CONTROL METHODS, REVISIONS TO DEFINITIONS	2009		YES		
R319.1	ADDRESS NUMBERS, SIZING OF LETTERS	2009		YES		
R322	FLOOD RESISTANT CONSTRUCTION	2009				REMOVED IN 2006 CODE
R323	ADDED STORM SHELTERS	2009				DO WE NEED THIS?
R401.3	SURFACE DRAINAGE , CHANGES TO DRAINAGE EXCEPTIONS	2009		YES	YES	DETAILS AND NOTES ON PLANS
R401.4	SOILS TESTS, REQUIREMENTS.	2009		YES	YES	REQUIRED TO USE BASEMENT WALLS AND FOOTINGS
R402.3	PRECAST CONCRETE FOUNDATION MATERIALS. ADDED MATERIAL SPECIFICATIONS.	2009		YES	YES	PROVIDE MANUFACTURER'S CUT SHEET TO MEET REQUIREMENTS.
R403.1.1	AMENDED TO ADD REQUIRED REBAR PLACEMENT.	COP	IN 2006 AMMENDMENTS	YES	YES	Moved to correct section
R403.1.3.2	SEISMIC REINFORCING FOR SLABS ON GRADE WITH TURNED DOWN FOOTINGS.	2009				SEISMIC 'D' ONLY
R403.1.6	FOUNDATION ANCHORAGE, REARRANGED FOR CLARITY.	2009		YES	YES	
R403.4	FOOTINGS FOR PRECAST FOUNDATIONS ADDED PRESCRIPTIVE REQUIREMENTS FOR FOUNDATION	2009		YES	YES	
R404.1(1) - 404.1(3)	LATERAL SUPPORT FOR CONCRETE AND MASONRY FOUNDATION WALLS. DELETED	2009				
R404.1	CONCRETE AND MASONRY FOUNDATION WALLS.	2009		YES	YES	COORDINATE WITH AMENDMENTS.

	ADDED APPLICABILITY LIMITS IN R611.2, MORE COMPREHENSIVE.					
R404.1.1(1)	REVISION TO PLAIN MASONRY WALLS	COP	IN 2006 AMMENDMENT.	YES	YES	
R404.1.1(5)	REVISIONS TO TABLE WITH FOOT NOTE m	COP	IN 2006 AMENDMENT	YES	YES	
R404.4(2) & R404.4(3)	REVISIONS TO TABLE WITH FOOTNOTE c	COP	IN 2006 AMENDMENT	YES	YES	
R404.1.9	ADDED ISOLATED MASONRY PIERS PRESCRIPTIVE CODE	2012		YES	YES	
R404.5	PRECAST CONCRETE FOUNDATION WALLS-REQUIRES DESIGN	2009		YES	YES	REQUIRES MANUFACTURERS CUT SHEET AND DESIGN STANDARDS.
R405.1	FOUNDATION DRAINAGE ADDED FILTER MEMBRANES	2012		YES	YES	
R405.1.1	PRECAST CONCRETE FOUNDATION DRAINAGE ADDED	2009		YES	YES	
R406.4	PRECAST CONCRETE FOUNDATION SYSTEM DAMP PROOFING	2009		YES	YES	
R407.3	STEEL PIPE COLUMNS CLARIFIED.	2009		YES	YES	
R408.1 & 408.2	UNDERFLOOR SPACE VENTILATION. REDUCTION W/ VAPOR BARRIER.	2009		YES	YES	
R501.3	ADDED FIRE PROTECTION OF FLOORS,	2012		YES	YES	VERIFY THIS COSTS
R502.2.2.1	ADDED DECK LEDGER ATTACHMENTS	2009		YES	YES	
R502.7	LATERAL RESTRAINT FOR WOOD JOIST PER MANUFACTURER SPECS	2009		YES	YES	
R505	COLD-FORMED STEEL FLOOR FRAMING, REVISED TO MATCH NEW STANDARDS, 3 STORY ALLOWED.	2009		YES	YES	
R507	ADDED DECKS MOVED FROM R502.2.2.1	2012		YES	YES	
R602.1.1	END JOINTED LUMBER, ADDED FIRE RESISTANT GLUE TO MARK.	2012		YES		
R602.3(1)	FASTNER SCHEDULE FOR STRUCTURAL MEMBERS	2009		YES		GYP BOARD TO BE 7" AND 7" FOR FASTNING.
R602.3(1)	REVISIONS TO FASTNER SCHEDLUE	2012		YES		
R602.3(3)	TABLE REVISED FOR WIND	2009		YES		
R602.3(5)	SIZE HEIGHT AND SPACING OF WOOD STUDS.	2009		YES		
R602.6.1	DRILLING AND NOTCHING OF TOP PLATE	2009		YES		NAIL PLATES.
R602.7.1	SINGLE MEMBER HEADERS	2012		YES	YES	

R602.10	EXTENSIVE REVISION TO WHOLE SECTION	2009 & 2012		YES	YES	WILL REQUIRE BWL GRIDS TO BE SHOWN ON PLANS WITH ALL BRACING TYPES AND CALCULATIONS SPECIFIED ON PLANS.
R602.11	WALL ANCHORAGE	2009		YES		
R602.12	ADDED SIMPLIFIED WALL BRACING	2012		YES	YES	WILL REQUIRE BWL GRIDS TO BE SHOWN ON PLANS WITH ALL BRACING TYPES AND CALCULATIONS SPECIFIED ON PLANS.
R603	STEEL WALL FRAMING REVISED TO STANDARDS, 3-STORY	2009		YES	YES	
R606.3 & R606.4	CORBELED MASONRY	2009		YES	YES	
R606.12.2.1	MINIMUM LENGTH OF MASONRY WALLS WITHOUT OPENINGS	2009		YES	YES	
R607.3	INSTALLATION OF WALL TIES	2012		YES	YES	
R611 & R612.2	EXTERIOR CONCRETE WALL CONSTRUCTION , WINDOW SILLS	2009		YES	YES	
R613	ADDED STRUCTURAL INSULATED PANEL WALL CONSTRUCTION	2009		YES	YES	MUST MEET ABLICABILITY STANDARDS. OR PROVIDE ENGINEERING
R702.3.5	3/8 CEILING BOARD NOTE 'd' REMOVED	COP	2006 AMENDMENTS			
R703.4	WEATHER-RESISTANT EXTERIOR COVERING	2009		YES	YES	NOTES AND DETAILS ON PLANS
R703.7.3	STEEL LINTELS	2009		YES	YES	NOTES AND DETAILS ON PLANS
R703.7.3.2	MASONRY VENEER LINTEL	2012		YES	YES	NOTES AND DETAILS ON PLANS
R703.7.4	MASONRY VENEER ANCHORAGE MIN EMBEDMENT	2009 & 2012		YES	YES	
R703.7.4.2	GROUT FILL BEHIND MASONRY VENEER	2012		YES	YES	MORTAR IS NO LONGER PERMITTED MUST BE GROUT.
R703.8	FLASHING	2012		YES	YES	MUST SHOW DESIGN FOR , OR INSTALLATION INSTRUCTION OF MANUFACTURER OF WINDOWS AND DOORS.
R703.11.1.1	SOFFIT PANELS AND SUPPORT	2009		YES	YES	
R703.11.2	FOAM PLASTIC SHEATHING	2009		YES	YES	DETAILS FOR NAIL PENETRATIONS.

R703.12	ADHERED MASONRY VENEER, MIN CLEARANCE AND FLASHING.	2012		YES	YES	SHOW CLEARANCES ON PLANS
R802.7	CUTTING, DRILLING, AND NOTCHING OF ROOF MEMBERS	2012		YES	YES	CEILING JOIST TAPERS
R802.11	ROOF UPLIFT RESISTANCE	2012		YES	YES	REVISED UPLIFT TABLES FOR STICK FRAME, MAX BUILDING WIDTH 32 FEET, MAX OVERHANG 24 INCHES.
R804	COLD FORMED STEEL ROOF FRAMING.	2009		YES	YES	DETAIL AND NOTES ON PLANS
R806	ATTIC VENTILATION- UNVENTED AND VAPOR BARRIORS	2009		YES	YES	CALCULATION AND DETAILS
R806	ATTIC VENTILATION- MIN VENT AREA CALCULATIONS, WEATHER PROTECTION	2012		YES	YES	CALCULATIONS AND DETAILS
R806.5	UNVENTED ATTIC ASSEMBLIES- USE OF INSULATION BOARDS	2012		YES	YES	DETAILS AND EDGE SEALING.
R807.1	ATTIC ACCESS	2009		YES	YES	NOTES AND DETAILS FOR NEW HEIGHT MEASUREMENTS.
R903.2.1	ROOF FLASHING LOCATIONS, FLASHING AT ROOF AND SIDE WALL LOCATIONS.	2012		YES	YES	DETAILS OR NOTES
R903.2.2	CRICKETS AND SADDLES, SKYLIGHTS.	2012		YES	YES	DETAILS AND NOTES
R903.6	CRICKET AND SADDLES	2006	AMENDMENTS FOR CHIMNEYS	YES	YES	STILL NEEDED
R905.2	ASPHALT SHINGLES- ASTM CHANGES, ATTACHEMENTS AND VALLEYS.	2009		YES	YES	DETAILS AND NOTES.
R905.2.7.2	UNDERLAYMENT AND HIGH WIND, FOR ADHERED UNDERLAYMENT	2012		NO	NO	NOT IN OUR AREA
R905.2.8.3	SIDEWALL FLASHING	2012		YES	YES	STEP OR STRAIGHT FLASHING
R905.2.8.5	ROOF DRIP EDGE REQUIRED FOR ASHAULT SHINGLE	2012		YES	YES	NOTES AND DETAILS.
R905.8.6	WOOD SHAKE INSTALLATION	2009		YES	YES	NOTES OR DETAILS.
R907.3	RECOVERING VERSUS REPLACEMENT OF ROOFING	2012				
R1001 & R1003	MASONRY FIREPLACES AND CHIMNEYS	2009		YES	YES	THICKNESS AND PARGE COATS.
R1003.9.1 & 3	MASONRY CHIMNEY CAPS AND RAIN CAPS	2012		YES		C
R1005.7	FACTORY BUILT CHIMNEY OFFSETS	2012		YES		
CHAPTER 11	ENERGY CODE- ENTIRE CODE SECTION	2009 &		YES	YES	WILL BE A SEPARATE LIST.

		2012				
M1301	IDENTIFICATION OF PIPE, TUBING AND FITTINGS	2012		YES		
M1305.1.4.1 & M1502.4	GROUND CLEARANCE FOR APPLIANCES	2009				PER MANUFACTURER
M1307.3.1	PROTECTION FROM IMPACT	2009		YES	YES	INTERIOR AND EXTERIOR
M1411.6	LOCKING ACCESS PORT CAPS	2012		YES		
M1502	CLOTHES DRYER EXHAUST	2009		YES	YES	COMPLETE REWRITE
M1502.4	DRYER EXHAUST DUCT	2012		YES		DUCT THICKNESS AND LENGTH
M1503.4	MAKEUP AIR FOR KITCHENS AND EXHAUST HOODS	2009		YES	YES	>400CFM MUST HAVE MAKE-UP AIR.
M1506	EXHAUST OPENINGS	2012		YES		
M1507	MECHANICAL VENTILATION	2012		YES	YES	WHOLE HOUSE VENTILATION
M1601.1	ABOVE GROUND DUCT SYSTEM	2012		YES	YES	CANT USE ON EXTERIOR WALLS.
M1601.3 & M1601.4	DUCT INSULATION MATERIALS AND DUCT INSTALLATION	2009		YES		
M1601.4.1	DUCT JOINTS, SEAMS, AND CONNECTIONS	2012		YES		MUST HAVE LISTED DUCT TAPE.
M1601.6	INDEPENDENT GARAGE HVAC SYSTEMS	2009		YES		
M1602.2	PROHIBITED SOURCES OF OUTDOOR AND RETURN AIR	2009 & 2012		YES	YES	MUST BRING FRESH AIR FROM OUTSIDE CANNOT USE ATTIC. DOES NOT INCLUDE COMBUSTION AIR. NEW EXCEPTION.
M1701	COMBUSTION AIR	2009		YES		MANUFACTURERS SPECS
M1901	RANGES AND OVENS	2012		YES		MANUFACTURERS SPECS
M2103.2	HYDRONIC FLOOR HEATING SYSTEMS	2009		YES	YES	INSULATION REQUIREMENTS.
M2104	HYDRONIC PIPING MATERIALS	2009		YES		MANUFACTURERS SPECS
M2301 & M2302	THERMAL AND PHOTOVOLTAIC SOLAR ENERGY SYSTEMS	2012		YES	YES	ENGINEERED DESIGN REQUIRED
G2408.2.1	APPLIANCE INSTALLATION IN GARAGES	2009		YES	YES	NO 18" IF ENCLOSED FROM GARAGE.
G2409.1	REDUCED CLEARANCE TO COMBUSTABLE MATERIALS	2012		YES		
G2412 & G2415	PIPE IDENTIFICATION AND CERTIFICATION	2012		YES		
G2419.4	UNDERGROUND PENETRATIONS PROHIBITED	2009		YES		
G2415.6	PIPING IN SOLID FLOORS	2009		YES	YES	VERIFY WITH UNISOURCE
G2415.12	PIPING UNDERGROUND BENEATH BUILDINGS	2009		YES	YES	
G2419.4	SEDIMENT TRAP	2012		YES		
G2420.5	APPLIANCE SHUTOFF VALVE	2009		YES	YES	APPLIANCE SHUT-OFF LOCATIONS

G2422.1.2.1	MAXIMUM LENGTH OF CONNECTORS	2009		YES		
G2439.5	CLOTHES DRYER DUCTS	2009		YES	YES	COMPLETE CHANGE
G2442.4	PROHIBITED SOURCES OF OUTDOOR AND RETURN AIR.	2012		YES		
G2447.5	VERTICAL CLEARANCE ABOVE COOKING TOP	2009		YES		
P2503.5.1	ROUGH PLUMBING TEST	2012		YES		DWV AIRTEST IS NO LONGER PERMITTED
P2601.2	CONNECTIONS TO DRAINAGE SYSTEMS	2012		YES	YES	GREY WATER
P2603.4	PIPES THROUGH FOUNDATION WALLS	2012		YES		
P2606	SEALING OF ANNULAR SPACE	2012		YES		
P2609.4 & P2609.4	IDENTIFICATION AND CERTIFICATION	2012		YES		
P2705.1	INSTALLATION OF FIXTURES	2009		YES		CLEARANCES REVISED.
P2702.1 & P2706.1	PLUMBING FIXTURES	2012		YES		
P2709.1 & P2709.2	SHOWER RECEPTORS AND LININGS	2012		YES	YES	
P2709.2.4	LIQUID-TYPE SHOWER LINING	2012		YES		
P2713.1	BATHTUB WASTE OUTLETS AND OVERFLOWS	2012		YES		
P2719.1	FLOOR DRAINS	2009			YES	
P2801.5	REQUIRED WATER HEATER PAN	2012		YES		EXEMPT TANKLESS HEATERS
P2902.6	LOCATION OF BACKFLOW PREVENTORS	2009		YES		
P3003.19	JOINTS BETWEEN DRAINAGE PIPING AND WATER CLOSET	2012		YES		CAN USE INTERNATION CONNECTION
P3005.2.6	CLEANOUT AT BASE OF STACKS	2009		YES		REQUIRED CAN'T BE OUTSIDE
P3007	SUMPS AND EJECTORS	2009		YES	YES	PIT DIMENSIONS
P3007.3.5	EJECTOR CONNECTION TO THE DRAINAGE SYSTEM	2012		YES	YES	PIT DIMENSIONS
P3009	GRAY-WATER RECYCLING SYSTEMS	2012		YES	YES	VERIFY WITH COUNTY
P3103.5	LOCATION OF VENT TERMINAL	2012		YES		
P3108.1 & 93108.2	WET VENTING	2009		YES	YES	PLUMBING DIAGRAM?
E3607.3	GROUNDING FOR BUILDINGS SUPPLIED BY FEEDERS	2009		YES		(INSPECTIONS)
E3608.1	GROUNDING ELECTRODES	2009		YES		
E3608.1.2	CONCRETE-ENCASED ELECTRODE.	2012		YES		(INSPECTIONS)
E3608.4	SUPPLEMENTAL ELECTRODE REQUIRED	2012		YES		(INSPECTIONS)
E3609.3	INTERSYSTEM BONDING TERMINATION	2009		YES		(INSPECTIONS)

E3705.7	LOCATION OF OVERCURRENT DEVICES	2009		YES	YES	
E3901	REQUIRED RECEPTACLE OUTLETS	2009		YES		
E3901.7	OUTDOOR OUTLETS	2009 & 2012		YES	YES	PER LEVEL ON EXTERIOR PROJECTION / DECKS
E3901.11	RECEPTACLE OUTLETS IN FOYERS	2012		YES	YES	
E3902.2 & E3902.5	GROUND FAULT CIRCUIT INTERRUPTER (GFCI) PROTECTION	2009		YES	YES	INCLUDES UNFINISHED BASEMENTS
E3902.11	LOCATION OF GROUND-FAULT CIRCUIT INTERRUPTERS	2012		YES	YES	NOT BEHIND APPLIANCES
E3902.12	ARC-FAULT PROTECTION	2009		YES	YES	INCLUDES ALL BUT BATH, KITCHEN AND GARAGE.
E3905.8	BOXES AT FAN OUTLETS	2012		YES		CEILING FAN BOXES
E4001.11.1	SWITCH AND FACEPLATE GROUNDING	2012		YES		
E4001.15	SWITCHES CONTROLLING LIGHTING LOADS	2012		YES		
E4002.14	TAMPER-RESESTANT RECEPTICLES	2009 & 2012		YES	YES	ALL OUTLETS WITH EXCEPTION FOR APPLIANCE AND GARAGE DOOR
E4003.12	LUMINAIRES IN CLOTHES SLOSETS	2009		YES	YES	NEW CONFUIRATIONS.
E4203.3	DISCONNECTION MEANS FOR POOLS, SPAS, AND HOT TUBS.	2009		YES	YES	
E4204.2	BONDING PARTS OF POOLS, SPAS, AND HOT TUBS.	2012		YES	YES	
E4206.5.1	SERVICING OF WET-NICHE LUMINAIRES	2009		YES	YES	
E4209.1	HYDROMASSAGE BATHTUBS	2009		YES		GFCI OUTLET ACCESSIBLE
E4209.3	ACCESSIBILITY TO ELECTRICAL EQUIPMENT OF HYDROMASSAGE BATHTUBS	2012		YES		LOCATION AND DISTANCE OF OUTLET.
AG105.2	OUTDOOR SWIMMING POOL BARRIER	2009		YES	YES	DOORS WITH ACCESS TO POOL AREAS
AG106	ENTRAPMENT PROTECTION FOR SWIMMING POOL AND SPA SUCTION OUTLETS	2009		YES	YES	CUT SHEETS