



CITY OF PRESCOTT, ARIZONA
"Everybody's Hometown!"

Purchasing Division
P.O. Box 2059
Prescott, AZ 86302

Phone: (928) 777-1203
Fax: (928) 777-1234
Tdd: (928) 777-1100

dawn.foster@cityofprescott.net

April 24, 2008

ALL PROSPECTIVE BIDDERS

ADDENDUM No. 1
08WPD0026 – Vertical Turbine Pump

Notice is hereby given that certain sections contained in the above referenced solicitation are being amended, clarified, and/or deleted and are identified as Addendum No. 1 and attached hereto.

THEREFORE: All bidders are required to note this Addendum No. 1 and indicate on Form A when submitting the bid package that it was received.

Should you have any questions, please contact the Purchasing Manager, Dawn Foster, at 928-777-1203.

Sincerely,

Dawn M. Foster

Attachment

ADDENDUM No. 1 for bid 08WPD0026
Vertical Turbine Pump

1. In Section “1.1 Pump Specifications” in the specifications chart, the lines “Column pipe Dia. – 10””, “Column pipe Length(s) – 47””, “Line shaft Dia. – 2-3/16””, “Head shaft Dia. – 2-3/16””, “Shaft Seal – John Crane Type 8B-1””, and the line, “Assembled pump and column pipe length MINUS the discharge head – 271-3/4””, **are deleted**.
2. Section “1.2 Additional Specifications” part 1.2.4 is **deleted**.
3. Section “1.2 Additional Specifications” part 1.2.5 is **deleted**.
4. Section “1.2 Additional Specifications” part 1.2.7 is **deleted**.
5. Section “1.2 Additional Specifications” part 1.2.9 is **amended** to read, “Supplier of pump bowl assembly shall be responsible for complete assembly of the pump bowl assembly unit only.”
6. The entire section “1.3 Installation Specifications” parts I.3.1 through parts I.3.11 is **deleted and replaced** with:

“1.3 Additional Requirements”
 - I.3.1 The pump bowl assembly shall match specifications for a Simflo vertical turbine pump serial number 106062 and/or Serial Number 46830-80 and be constructed and adapted to match existing equipment.
 - 1.3.2 This purpose of this bid is to purchase a spare, fully assembled, pump bowl assembly unit only. No installation, column piping, discharge head, shafting, or shaft seal is required.
 - 1.3.3 The pump shall be delivered to 1481 Sundog Ranch Rd. Prescott, AZ 86301.
 - 1.3.4 The pump shall be delivered within 17 weeks from bid opening.