



NOTES:

1. NO OBSTRUCTIONS ON ONE SIDE.
2. BACKFLOW PROTECTION REQUIRED PER CITY/TOWN CODE.
3. ENCLOSURE REQUIRED (ASSE 1060 CLASS 1).
4. ALL CONNECTIONS SHALL BE FLANGED OR MECHANICALLY RESTRAINED JOINTS.
5. THERE SHALL NOT BE ANY CONNECTIONS ON THE SERVICE LINE BETWEEN THE RP AND THE WATER METER. ENCLOSURES INSTALLED MUST MEET CLEARANCE REQUIREMENTS IN ADDITION TO PROVIDING SIDE AND TOP ACCESS. ENCLOSURES MUST NOT RETAIN WATER.
6. THE ASSEMBLY SHALL BE ACCESSIBLE AT ALL TIMES.

7. DISTANCE FROM THE BOTTOM OF PRESSURE RELIEF VALVE TO THE FINISHED GRADE SHALL BE A MINIMUM OF TWICE THE DIAMETER OF THE ASSEMBLY PIPING. MINIMUM HEIGHT 12".
8. INSTALLATION MUST MEET INTERNATIONAL PLUMBING CODES IN ADDITION TO STANDARD WATER DETAILS. INSTALLATION MUST BE LEFT EXPOSED UNTIL INSPECTED AND APPROVED BY THE CITY/TOWN.
9. RP SHALL BE LOCATED ABOVE GROUND AND ENCLOSED IN AN ASSE 1060 CLASS 1 APPROVED ENCLOSURE PER INTERNATIONAL BUILDING CODES.
10. RP SHALL BE LOCATED WITHIN 4' OF METER, UNLESS OTHERWISE APPROVED.

11. DOUBLE CHECK VALVE BACKFLOW PREVENTION ASSEMBLY USE SHALL BE REVIEWED AND APPROVED BY AGENCY.
12. ASSEMBLY SHALL BE APPROVED BY USC FOUNDATION FOR CROSS-CONNECTION CONTROL AND HYDRAULIC RESEARCH.