

ADDENDUM NUMBER THREE

FOR THE

ZONE 41 MINGUS PUMP STATION, TANK AND PIPELINE

DATE OF ADDENDUM: April 18, 2024

TO ALL BIDDERS BIDDING ON THE ABOVE PROJECT:

The following addendum shall be made part of the Project Specifications and Contract Documents. All other provisions of the Contract Documents remain unchanged. The Bidder shall acknowledge receipt of this Addendum on page 13 of the Bid Proposal form, in addition to signing below and returning this form with the bid package. The contents of this Addendum shall be given full consideration in the preparation of the Bid.

Requests for Information (RFI)

Question: 1. Per 09 97 13.33, PART 2 PRODUCTS, 2.02 COATING SYSTEM, A. General:, D. Inside Coating: 1. It identifies that the interior coating system shall be NSF 61. This standard is no longer applied. The New standard is NSF 600

Response: Specification Section 09 97 13.33, Section 1.02.A.2 states the following: “Unless otherwise specified, references to documents shall mean the documents in effect at the time of Advertisement for Bids or Invitation to Bid (or on the effective date of the Agreement if there were no Bids). If referenced documents have been discontinued by the issuing organization, references to those documents shall mean the replacement documents issued or otherwise identified by that organization or, if there are no replacement documents, the last version of the document before it was discontinued. Where document dates are given in the following listing, references to those documents shall mean the specific document version associated with that date, regardless of whether the document has been superseded by a version with a later date, discontinued or replaced”. It is appropriate to use the most current reference (NSF 600) as applicable to the coating systems.

- END -

City of Prescott Public Works Department

Gwen Rowitsch, Public Works Director

Date

Acknowledgement: (must be signed and turned in with the bid documents)

Company Name

Signature of Company Official

Date