



ADDENDUM NUMBER ONE
FOR THE
FIRE STATION 71 CLEAN ROOM

DATE OF ADDENDUM: September 11, 2025

TO ALL BIDDERS BIDDING ON THE ABOVE PROJECT:

The following addendum shall be made part of the Project Specifications and Contract Documents. All other provisions of the Contract Documents remain unchanged. The Bidder shall acknowledge receipt of this Addendum on page 9 of the Bid Proposal form, in addition to signing below and returning this form with the bid package. The contents of this Addendum shall be given full consideration in the preparation of the Bid.

Requests for Information

Question: Has there been an environmental report completed?

Response: Yes. They are attached to this addendum.

Question: Will the architect be providing a spec for the 2x4 acoustical ceiling grid and tile?

Response: No. The items used will just be a standard tile and grid.

Question: Liquidated damages are indicated in the Sample Contract, what are the liquidated damages set at for this project?

Response: This will be determined when the value of the project is awarded.

Question: Item 5 on the Bid Schedule refers to Additive Alternates; are there any additive alternates that we should be providing pricing on at this time?

Response: None at this time.

Question: Please confirm that all permit fees are to be paid by the owner. Please also confirm if drawings have already been submitted and reviewed by the AHJ.

Response: Yes, the fees are to be paid by the owner. Yes, the plans have been submitted and reviewed.

Question: Are there specific door hardware specifications for manufacturers, models, types, etc. beyond what is shown in A-501?

Response: No

Question: Please provide clarification on door material FMC-HC in the Door Schedule on Sheet A-501.

Response: Standard commercial metal door.

Question: The Finish Schedule on A-501 shows the ceiling material to be GWB, both rooms at 10'0" A.F.F.; Sheet A-402 shows the ceilings as ACT at 9'0" and 10'0" – please confirm ceiling heights, type, and material (i.e. ceiling tile spec).

Response: Use sheet A-402

Question: Detail 11 on Sheet A-501 calls out for all new walls to be taped and textured, please confirm texture is to match existing troweled texture.

Response: Yes

Question: Keynote 10.02 on Sheet A-401 states “Turnout Lockers - New and Existing (14 total)”, is the contractor providing the new lockers and, if so, how many new lockers will need to be provided and is there a spec for the new lockers? Please also confirm if contractor is responsible for installation of all lockers.

Response: City will purchase new lockers and install old ones.

Question: Keynote 3 on Sheet M2.0 calls out for the existing mechanical equipment to be relocated and references the Architectural plans for height; please confirm height of mechanical unit.

Response: This refers to the current AirHawk unit and will be located in same space just below ceiling grid.

Question: What are the preferred specifications for the ceiling grid and ceiling tile?

Response: Standard grid and tiles.

Question: For the existing eyewash station noted on keynote 22.01, will it be replaced or reused? If replacement is required, please confirm the preferred specification.

Response: The eye station will be re-used.

Question: Sheet M-0 Mechanical Schedule, the Schedule calls for Notes 1, 2, 4, 5 & 6. There are no notes 5 & 6, please advise.

Response: That is a clerical error as you are correct, there are no notes 5 & 6. Just use the listed notes.

Question: The current Air Hawk system is only shown on E-2 for its new location (room 120). Please verify if this is correct and if the unit will be below the ceiling, if so do the new lights need to be reconfigured?

Response: Yes, this is correct. And the unit will go below the ceiling working around the lights. Exact location of air hawk isn't important as long as it is not interfering with lights.

Question: A-501 is calling ceilings to be framed hard lids, A-402 is calling the ceiling to be Suspended Acoustical Ceiling System. Please clarify.

Response: Acoustical Ceiling System.

Question: Will surface mounted piping be ok on the CMU wall? Will all existing surface mounted conduit and piping remain and be painted?

Response: Yes, and yes.

Question: Please provide the City standard specification for the door hardware. Manufacture, keying type, etc.

Response: Schlage commercial ADA compliant with min 5 pin tumbler.

Question: Have the permits been applied for? Will the Notice to Proceed be issued after permits are ready?

Response: Yes, they have been and yes once the permit is issued, but we anticipate the permit in the next week.

Question: The plan notes 10.2 calls for New and existing lockers. Please provide a count and spec for the new locker.

Response: City will supply lockers and install.

Question: The bid schedule is missing a few items. For example, demo, doors & hardware, accessories (paper towel dispenser, etc.), floor sealer & base, FRP, insulation, ceilings. Shall these items be added to the bid schedule or be spread out into the existing items on the bid schedule. If the bid schedule is reissued, please provide an excel version.

Response: Spread out into existing items.

- END -

City of Prescott Recreation Services Department

Tim Legler
Tim Legler, Deputy Recreation Services Director

9.10.2025
Date

Acknowledgement: (must be signed and turned in with the bid documents)

Company Name

Signature of Company Official

Date

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Asbestos Chain of Custody

EMSL Order Number (Lab Use Only):

121505342

Phoenix, AZ 85017

PHONE: (602) 276-4344

FAX: (602) 276-4053

Company: Western Technologies, Inc.		EMSL Bill to: <input type="checkbox"/> Different <input checked="" type="checkbox"/> Same If Bill to is Different note instructions in Comments	
Street: 1040 Sandretto Drive Suite C		Third Party Billing requires written authorization from third party	
City: Prescott	State/Province: AZ	Zip/Postal Code: 86305	Country: United States
Report To (Name): Kathleen Frost		Telephone #: 928-899-3942	
Email Address: k.frost@wt-us.com		Fax #: 928-443-7392	Purchase Order:
Project Name/Number: 258 SJ K052		Please Provide Results: <input type="checkbox"/> FAX <input checked="" type="checkbox"/> 4 <input type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: AZ		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	
Turnaround Time (TAT) Options* - Please Check			
<input type="checkbox"/> 3 Hour <input type="checkbox"/> 6 Hour <input type="checkbox"/> 24 Hour <input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input checked="" type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week			
*For TEM Air 3 hr through 6 hr, please call ahead to schedule. *There is a premium charge for 3 Hour TEM AHERA or EPA Level II TAT. You will be asked to sign an authorization form for this service. Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide.			
PCM - Air <input type="checkbox"/> Check if samples are from NY <input type="checkbox"/> NIOSH 7400 <input type="checkbox"/> w/ OSHA 8hr. TWA		TEM - Air <input type="checkbox"/> 4-4.5hr TAT (AHERA only) <input type="checkbox"/> AHERA 40 CFR, Part 763 <input type="checkbox"/> NIOSH 7402 <input type="checkbox"/> EPA Level II <input type="checkbox"/> ISO 10312	
PLM - Bulk (reporting limit) <input checked="" type="checkbox"/> PLM EPA 600/R-93/116 (<1%) <input type="checkbox"/> PLM EPA NOB (<1%) Point Count <input type="checkbox"/> 400 (<0.25%) <input type="checkbox"/> 1000 (<0.1%) Point Count w/ Gravimetric <input type="checkbox"/> 400 (<0.25%) <input type="checkbox"/> 1000 (<0.1%) <input type="checkbox"/> NYS 198.1 (friable in NY) <input type="checkbox"/> NYS 198.6 NOB (non-friable-NY) <input type="checkbox"/> NIOSH 9002 (<1%)		TEM - Bulk <input type="checkbox"/> TEM EPA NOB <input type="checkbox"/> NYS NOB 198.4 (non-friable-NY) <input type="checkbox"/> Chatfield SOP <input type="checkbox"/> TEM Mass Analysis-EPA 600 sec. 2.5 TEM - Water: EPA 100.2 Fibers >10µm <input type="checkbox"/> Waste <input type="checkbox"/> Drinking All Fiber Sizes <input type="checkbox"/> Waste <input type="checkbox"/> Drinking	
TEM - Dust <input type="checkbox"/> Microvac - ASTM D 5755 <input type="checkbox"/> Wipe - ASTM D6480 <input type="checkbox"/> Carpet Sonication (EPA 600/J-93/167)		Soil/Rock/Vermiculite <input type="checkbox"/> PLM CARB 435 - A (0.25% sensitivity) <input type="checkbox"/> PLM CARB 435 - B (0.1% sensitivity) <input type="checkbox"/> TEM CARB 435 - B (0.1% sensitivity) <input type="checkbox"/> TEM CARB 435 - C (0.01% sensitivity) <input type="checkbox"/> TEM Qual. via Filtration Technique <input type="checkbox"/> TEM Qual. via Drop-Mount Technique	
<input type="checkbox"/> Check For Positive Stop - Clearly Identify Homogenous Group		Filter Pore Size (Air Samples): <input type="checkbox"/> 0.8µm <input type="checkbox"/> 0.45µm	
Samplers Name: Kathleen Frost		Samplers Signature: K. Frost	
Sample #	Sample Description	Volume/Area (Air) HA # (Bulk)	Date/Time Sampled
052-11/10-01	Bay Restroom 12" beige ceramic floor	1	11/10/15 11:10
-02	tile w/ grout (gray)	↓	
-03	4" thin set	↓	
-04	light knock-down	2	
-05	drywall system	↓	
-06	drywall system	↓	
-07	2nd floor orange peel	3	
-08	stairwell drywall	↓	
-09	seplen	↓	
Client Sample # (s): 052-11/10-01 to -24		Total # of Samples: 24	
Relinquished (Client): KF/WT		Date: 11-10-15	1330
Received (Lab): [Signature]		Date: 11/11/15	Time: 9:45 AM
Comments/Special Instructions: (7950 0084 10752)			



EMSL ANALYTICAL, INC.
LABORATORY SERVICES • 800 • 833 • 8888

EMSL Order Number (Lab Use Only):

121505342

FAX: (602) 276-4053

Jan. closet

Page 2 of 2 pages



EMSL Analytical, Inc.

3356 West Catalina Drive Phoenix, AZ 85017

Tel/Fax: (602) 276-4344 / (602) 276-4053

<http://www.EMSL.com> / phoenixlab@emsl.com

EMSL Order: 121505342

Customer ID: WTCN78

Customer PO:

Project ID:

Attention: Kathleen Frost
Western Technologies, Inc.
1040 Sandretto Drive
Suite C
Prescott, AZ 86305
Project: 2585JK052 / Station 71

Phone: (928) 899-3942
Fax: (928) 443-7392
Received Date: 11/11/2015 9:45 AM
Analysis Date: 11/16/2015
Collected Date: 11/10/2015

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	% Fibrous	Non-Asbestos	Asbestos
				% Non-Fibrous	% Type
052-11/10-01-Ceramic Tile <i>121505342-0001</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Tan/Beige Non-Fibrous Heterogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-01-Grout <i>121505342-0001A</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-01-Thinset <i>121505342-0001B</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-02-Ceramic Tile <i>121505342-0002</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Tan/Beige Non-Fibrous Heterogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-02-Grout <i>121505342-0002A</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-02-Thinset <i>121505342-0002B</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-03-Ceramic Tile <i>121505342-0003</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Tan/Beige Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-03-Grout <i>121505342-0003A</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-03-Thinset <i>121505342-0003B</i>	Bay Restroom - 12" Beige Floor Ceramic Tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-04-Texture <i>121505342-0004</i>	Bay Restroom - Light Knock-Down Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-04-Tape <i>121505342-0004A</i>	Bay Restroom - Light Knock-Down Drywall System	Yellow Fibrous Homogeneous	99% Glass	1% Non-fibrous (Other)	None Detected
052-11/10-04-Drywall <i>121505342-0004B</i>	Bay Restroom - Light Knock-Down Drywall System	Brown/White Fibrous Heterogeneous	10% Cellulose	85% Gypsum 5% Non-fibrous (Other)	None Detected
052-11/10-05-Texture <i>121505342-0005</i>	Bay Restroom - Light Knock-Down Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-05-Tape <i>121505342-0005A</i>	Bay Restroom - Light Knock-Down Drywall System	Yellow Fibrous Homogeneous	99% Glass	1% Non-fibrous (Other)	None Detected
052-11/10-05-Drywall <i>121505342-0005B</i>	Bay Restroom - Light Knock-Down Drywall System	Brown/White Fibrous Heterogeneous	10% Cellulose	85% Gypsum 5% Non-fibrous (Other)	None Detected



EMSL Analytical, Inc.

3356 West Catalina Drive Phoenix, AZ 85017

Tel/Fax: (602) 276-4344 / (602) 276-4053

<http://www.EMSL.com> / phoenixlab@emsl.com

EMSL Order: 121505342

Customer ID: WTCN78

Customer PO:

Project ID:

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	<u>Non-Asbestos</u>		<u>Asbestos</u>
			% Fibrous	% Non-Fibrous	% Type
052-11/10-06-Texture 121505342-0006	Bay Restroom - Light Knock-Down Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-06-Tape 121505342-0006A	Bay Restroom - Light Knock-Down Drywall System	Yellow Fibrous Homogeneous	99% Glass	1% Non-fibrous (Other)	None Detected
052-11/10-06-Drywall 121505342-0006B	Bay Restroom - Light Knock-Down Drywall System	Brown/White Fibrous Heterogeneous	10% Cellulose	85% Gypsum 5% Non-fibrous (Other)	None Detected
052-11/10-07-Texture 1 121505342-0007	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-07-Texture 2 121505342-0007A	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-07-Tape 121505342-0007B	2nd Floor Stairwell - Orange Peel Drywall System	Beige Fibrous Homogeneous	99% Cellulose	1% Non-fibrous (Other)	None Detected
052-11/10-07-Joint Compound 121505342-0007C	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-07-Drywall 121505342-0007D	2nd Floor Stairwell - Orange Peel Drywall System	Brown/White Fibrous Heterogeneous	10% Cellulose 2% Glass	85% Gypsum 3% Non-fibrous (Other)	None Detected
052-11/10-08-Texture 1 121505342-0008	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-08-Texture 2 121505342-0008A	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-08-Tape 121505342-0008B	2nd Floor Stairwell - Orange Peel Drywall System	Beige Fibrous Homogeneous	99% Cellulose	1% Non-fibrous (Other)	None Detected
052-11/10-08-Joint Compound 121505342-0008C	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-08-Drywall 121505342-0008D	2nd Floor Stairwell - Orange Peel Drywall System	Brown/White Fibrous Heterogeneous	10% Cellulose 2% Glass	85% Gypsum 3% Non-fibrous (Other)	None Detected
052-11/10-09-Texture 1 121505342-0009	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-09-Texture 2 121505342-0009A	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-09-Tape 121505342-0009B	2nd Floor Stairwell - Orange Peel Drywall System	Beige Fibrous Homogeneous	99% Cellulose	1% Non-fibrous (Other)	None Detected
052-11/10-09-Joint Compound 121505342-0009C	2nd Floor Stairwell - Orange Peel Drywall System	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-09-Drywall 121505342-0009D	2nd Floor Stairwell - Orange Peel Drywall System	Brown/White Fibrous Heterogeneous	10% Cellulose 2% Glass	85% Gypsum 3% Non-fibrous (Other)	None Detected



EMSL Analytical, Inc.

3356 West Catalina Drive Phoenix, AZ 85017

Tel/Fax: (602) 276-4344 / (602) 276-4053

<http://www.EMSL.com> / phoenixlab@emsl.com

EMSL Order: 121505342

Customer ID: WTCN78

Customer PO:

Project ID:

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	<u>Non-Asbestos</u>		<u>Asbestos</u>
			% Fibrous	% Non-Fibrous	% Type
052-11/10-10-Texture 1 <i>121505342-0010</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-10-Texture 2 <i>121505342-0010A</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-10-Tape <i>121505342-0010B</i>	1st Level Office RR Jan. Closet - Orange Peel	Beige Fibrous Homogeneous	99% Cellulose	1% Non-fibrous (Other)	None Detected
052-11/10-10-Joint Compound <i>121505342-0010C</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-10-Drywall <i>121505342-0010D</i>	1st Level Office RR Jan. Closet - Orange Peel	Brown/White Fibrous Heterogeneous	10% Cellulose 2% Glass	85% Gypsum 3% Non-fibrous (Other)	None Detected
052-11/10-11-Texture 1 <i>121505342-0011</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-11-Texture 2 <i>121505342-0011A</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-11-Tape <i>121505342-0011B</i>	1st Level Office RR Jan. Closet - Orange Peel	Beige Fibrous Homogeneous	99% Cellulose	1% Non-fibrous (Other)	None Detected
052-11/10-11-Joint Compound <i>121505342-0011C</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-11-Drywall <i>121505342-0011D</i>	1st Level Office RR Jan. Closet - Orange Peel	Brown/White Fibrous Heterogeneous	10% Cellulose 2% Glass	85% Gypsum 3% Non-fibrous (Other)	None Detected
052-11/10-12-Texture 1 <i>121505342-0012</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-12-Texture 2 <i>121505342-0012A</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-12-Tape <i>121505342-0012B</i>	1st Level Office RR Jan. Closet - Orange Peel	Beige Fibrous Homogeneous	99% Cellulose	1% Non-fibrous (Other)	None Detected
052-11/10-12-Joint Compound <i>121505342-0012C</i>	1st Level Office RR Jan. Closet - Orange Peel	White Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-12-Drywall <i>121505342-0012D</i>	1st Level Office RR Jan. Closet - Orange Peel	Brown/White Fibrous Heterogeneous	10% Cellulose 2% Glass	85% Gypsum 3% Non-fibrous (Other)	None Detected
052-11/10-13-Floor Tile <i>121505342-0013</i>	2nd Floor Office - 12" - Blue Speckled Floor Tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-13-Glue <i>121505342-0013A</i>	2nd Floor Office - 12" - Blue Speckled Floor Tile	Yellow Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-14-Floor Tile <i>121505342-0014</i>	2nd Floor Office - 12" - Blue Speckled Floor Tile	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected



EMSL Analytical, Inc.

3356 West Catalina Drive Phoenix, AZ 85017

Tel/Fax: (602) 276-4344 / (602) 276-4053

<http://www.EMSL.com> / phoenixlab@emsl.com

EMSL Order: 121505342

Customer ID: WTCN78

Customer PO:

Project ID:

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	<u>Non-Asbestos</u>		<u>Asbestos</u>
			% Fibrous	% Non-Fibrous	% Type
052-11/10-14-Glue 121505342-0014A	2nd Floor Office - 12" - Blue Speckled Floor Tile	Yellow Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-15-Floor Tile 121505342-0015	1st Floor Jan. Closet - 12" - Blue Speckled Floor	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-15-Glue 121505342-0015A	1st Floor Jan. Closet - 12" - Blue Speckled Floor	Yellow Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-16-Floor Tile 121505342-0016	1st Floor Office RR - 12" Salmon Speckled Floor	Beige Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-16-Glue 121505342-0016A	1st Floor Office RR - 12" Salmon Speckled Floor	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-17-Floor Tile 121505342-0017	1st Floor Office RR - 12" Salmon Speckled Floor	Beige Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-17-Glue 121505342-0017A	1st Floor Office RR - 12" Salmon Speckled Floor	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-18-Floor Tile 121505342-0018	1st Floor Office RR - 12" Salmon Speckled Floor	Beige Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-18-Glue 121505342-0018A	1st Floor Office RR - 12" Salmon Speckled Floor	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-19-Floor Tile 121505342-0019	1st Level Offices Off Main Entrance - 12" Gray	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-19-Glue 121505342-0019A	1st Level Offices Off Main Entrance - 12" Gray	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-20-Floor Tile 121505342-0020	1st Level Offices Off Main Entrance - 12" Gray	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-20-Glue 121505342-0020A	1st Level Offices Off Main Entrance - 12" Gray	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-21-Floor Tile 121505342-0021	1st Level Offices Off Main Entrance - 12" Gray	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-21-Glue 121505342-0021A	1st Level Offices Off Main Entrance - 12" Gray	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-22-Floor Tile 121505342-0022	Lower Level Quarters Hall & Office - 12" Blue-Gray	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-22-Glue 121505342-0022A	Lower Level Quarters Hall & Office - 12" Blue-Gray	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-23-Floor Tile 121505342-0023	Lower Level Quarters Hall & Office - 12" Blue-Gray	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
052-11/10-23-Glue 121505342-0023A	Lower Level Quarters Hall & Office - 12" Blue-Gray	Tan Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected



EMSL Analytical, Inc.

3356 West Catalina Drive Phoenix, AZ 85017

Tel/Fax: (602) 276-4344 / (602) 276-4053

<http://www.EMSL.com> / phoenixlab@emsl.com

EMSL Order: 121505342

Customer ID: WTCN78

Customer PO:

Project ID:

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	<u>Non-Asbestos</u>		<u>Asbestos</u>
			% Fibrous	% Non-Fibrous	% Type
052-11/10-24-Floor Tile	Lower Level Quarters	Gray		100% Non-fibrous (Other)	None Detected
	Hall & Office - 12"	Non-Fibrous			
121505342-0024	Blue-Gray	Homogeneous			
052-11/10-24-Glue	Lower Level Quarters	Tan		100% Non-fibrous (Other)	None Detected
	Hall & Office - 12"	Non-Fibrous			
121505342-0024A	Blue-Gray	Homogeneous			

Analyst(s)

Bradley Orlowski (48)

Peter Donato (24)

Michelle Wilson

Michelle Wilson, Laboratory Manager
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Reporting limit is 1%

Samples analyzed by EMSL Analytical, Inc. Phoenix, AZ NVLAP Lab Code 200811-0, AZ0937

Initial Report From: 11/17/2015 17:23:30