

City of Prescott 2024 International Fuel Gas Code Significant Changes

CODE SECTION	SCOPE OF CODE CHANGE	CODE CHANGE YEAR	TYPE OF CHANGE TO CODE SECTION	FIELD INSPECTION	NOTES ON PLANS	DETAILS ON PLANS	MISC. NOTES
202	New Definition: Press-Connect Joint: A permanent mechanical joint incorporating an elastomeric seal or an elastomeric seal and corrosion resistant grip or bite fitting. The joint is made with a pressing tool and jaw or ring approved by the fitting manufacturer.	2021	Modification				
307.2	Concealed Condensate Piping: The termination of concealed condensate piping shall be marked to indicate whether the piping is connected to the primary drain or to the secondary drain.	2021	Modification			X	
402.7	The code now recognizes press-connect joints as suitable for high pressure (over 5 psig) application indoors.					X	
406.7.3.1	Abandoned fuel gas piping. Where fuel gas piping is removed from service for an indefinite time period, it shall be purged.	2024	Addition			X	
503.10.7	Vent Connector Junctions: New text addresses the juncture of appliance vent connectors and the required method. :the connection shall be made with a tee or wye fitting. (field made fittings are not allowed)	2021	Addition			X	
614.7	Clothes Dryer Make-up air: Installations exhausting more than 200 cfm shall be provided with makeup air.	2021	Clarification			X	
614.7	Clothes Dryer Make-up air: Where a closet is designed for the installation of a clothes dryer, an opening having an area of not less than 100 square inches for makeup air shall be provided in the closet enclosure, or makeup air shall be provided by other means.	2021	Clarification			X	
Appendix A	Sizing and Capacities of Gas Piping (IFGS). Appendix A provides commentary, guidance and examples for sizing of gas piping systems.	2024	Adopt				
Appendix B	Sizing of Venting Systems Serving Appliances Equipped With Draft Hoods, Category I Appliances and Appliances Listed for Use With Type B Vents (IFGS). Appendix B provides commentary, guidance and examples for the design of venting systems for the types of appliances that vent by natural draft and have draft hoods or are listed as Category I or are listed for use with Type B vents.	2024	Adopt				

City of Prescott 2024 International Fuel Gas Code Significant Changes

CODE SECTION	SCOPE OF CODE CHANGE	CODE CHANGE YEAR	TYPE OF CHANGE TO CODE SECTION	FIELD INSPECTION	NOTES ON PLANS	DETAILS ON PLANS	MISC. NOTES
Appendix C	Recommended Procedure for Safety Inspection of an Existing Appliance Installation (IFGS). Appendix C provides procedures for testing and inspecting existing gas appliance installations for safe operation.	2024	Delete				
Appendix D	Board of Appeals (IFGC). Appendix D provides criteria for Board of Appeals members. Also provided are procedures by which the Board of Appeals should conduct its business.	2024	Delete				